Fire Prevention Bureau
533 "C" Street
Eureka, California 95501-0340
Telephone (707) 441-4000
Fax (707) 441-4133
E-mail: eurekafd@ci.eureka.ca.gov

CITY OF EUREKA
FIRE DEPARTMENT INSPECTION REPORT

White Copy–Business
Yellow Copy–Occupancy File
Pink Copy–Station File

Inspection Cycle: 1 Year ✓ 3 Year ___
200 10 200 ___ 200 ___

Block No. C/R

Address: 7351 Tompkins Hill Rd	Business Name: College of the Redwoods
Business Phone: 476-4112	Business Fax:
Contact 1: George Kapitan	Phone(s): 476-4111
Contact 2: Tim Flannagan	Phone(s): 668-5461
Building Owner: Chuck Snowden	Phone(s): 445-1981
Address:	Occupancy Class: A/E/L Firehouse Entry:

AN INSPECTION OF YOUR FACILITY REVEALED THE FOLLOWING:

	Fire Extinguishers: Due for service, required		Exit(s) obstructed, inadequate
	Extension cords: Excessive use, defective		Exit sign(s) required, illumination
	Excessive rubbish, trash, debris		Exit sign lights need replacing
	Fire alarm system defective		Exit lighting: Required, defective
	Sprinkler system: Service required, defective		Smoke Alarms: Required, defective
	Kitchen hood extinguishing system service due		Wiring: Exposed, damaged, connectors, etc.
	Fire walls, ceilings, fire doors, draft stops		Heating system: Defective appliance, flue, combustibles
	Knox Box Contents		Other:

DETAILED EXPLANATION AND CORRECTIONS: CORRECTED:

- Repair exit lights in gym and in hallway by weightroom COMPLETE 1/22/11
- Eureka Oxygen on site servicing extinguishers and hood system. COMPLETE 12/23/10
- Install 2A10BC in computer lab in library. W.O. 15047-14622 COMPLETE 1/5/11
- Maintenance to ensure exit lights are operational in classrooms prior to school beginning COMPLETE 1/5/11

Date: 12-21-10	Discussed with: (Print) George Kapitan	Signed:
Shift A___ B___ C✓	Station: HQ___ Sta 3✓ Sta 4___ FPB___	Inspecting Officer: (Print) Gossien # 432

FIRE PREVENTION SAVES LIVES, PROPERTY, AND BUSINESS. YOUR COOPERATION WITH CORRECTING THE ABOVE LISTED ITEMS IS APPRECIATED.

RE-INSPECTION DATE: